



## Dry Well

3742 West Front Street - Traverse City, MI 49684-8152 - 231-946-7880 - www.theconcreteservice.com





## Notes:

- 1. Typical wall thickness is 3.5"
- 2. End inlet is fitted with polylock accepting pipes up to 6" dia.
- 3. Concrete access lid(s) shown are included
- 4. Dimensions shown are approximate only
- 5. Tank may have internal support ribs or similar structures not shown above

## #600DW

Outside Dim. 60W x 108L x 41H Total Weight 4,000 lbs Capacity 600 ga.